

SISTEM ZG. POLSKAVA

PARAMETER	12.01.2024	20.03.2024	20.03.2024	28.05.2024	01.10.2024	20.12.2024	05.04.2024	20.12.2024	13.03.2024	28.05.2024	04.09.2024	20.11.2024
	KAMENČEK	KAMENČEK	MAGDIČ	KAMENČEK	KAMENČEK	KAMENČEK	ZAGORKA	ZAGORKA	MONITORING	MONITORING	MONITORING	MONITORING
Temperatura	8,2	10,8	11,7	16,7	16,7	9,7	12,9	10,1	9,7	15,6	22	12,2
motnost					0,1	0,1	0,1		0,13		0,15	
pH vrednost					7,8	7,8	7,6		7,8	7,9	7,8	7,5
elektr.prevod.					276	278	2740		412	268	300	283
okus, vonj					brez.posebn.	brez.posebn.	brez.posebn.		1	0	0	1
enterokoki	0	0	0	0	0	0	0	0	0	0	0	0
količnine bakt.	0	0	0	0	5(meja 0)	4>(meja 0)	0	1(meja 0)	0	0	0	6(meja 0)
E- coli	0	0	0	0	0	0	0	0	0	0	0	0
Clostrid.perfringens	0	0	0	0	0	0	0		0	0	0	0
št. Kolonij pri 36 st.	< 10	< 10	20	< 10	14	< 10	38	130(meja 100)	< 10	< 10	< 10	< 10
št kolonij pri 24 st.	< 10	< 10	< 10	< 10	< 10	< 10	10	72	< 10	< 10	< 10	< 10
Bromat				<2								
bromidklorometan				0,44								
dibromklorometan				0,57								
tribrommetan				< 0,2								
triklorometan				0,2								
trihalometani				0,2								
klorat				< 0,01								
klorid				8,9								

